

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 108

Date 12/08/26

It is certified that an inspection team headed by Dr. Sanjay Das, Medical Officer In Charge (MOIC) from Primary Health Center, Hajipur inspected Virtuous International K-12 School, Minapur, Hajipur, Vaishali on 11/08/2026 and on the basis of Water Test Report (attached) vide Letter no.73 dtd. 25/5/26 of Chemist PHED Divisional Lab Hajipur, has found that Virtuous International K-12 School, Minapur, Hajipur, Vaishali has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/U.T Govt.

The above is valid till ... 11/08/27

Signature with Seal:

Pm 12-8-26
Medical Officer Incharge
Primary Health Centre
Hajipur (Vaishali) *SPM 12/8*

Name : Dr. Sanjay Das

Designation : MOIC

Name and Address of Department : Primary Health Center, Hajipur

To,

Virtuous International K-12 School
Minapur, Hajipur, Vaishali

VJ
Principal
Virtuous International K-12 School
Hajipur, Vaishali (Bihar)

HA
Chairman
Virtuous International K-12 School
Hajipur, Vaishali (Bihar)

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

District Name:- Vaishali				Division Name:- Hajipur				Sample Collect by:- Self										Month:- April-2026								Format:- I		
Sl. No.	Block	Ward / Panchayat	Village	Name of Habitation	Location of Source	Village Code	Population	Latitude		Longitude		pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	AL	F	Report handed over Beneficiary or not	Demonstration of contaminated source	Data online or not	Remarks			
								N	Min.	E	Min.															Sec.	Sec.	
1	Hajipur	Ward 17		Mihapur	Virtuous International K-12 School																							
Permissible Limit												6.5-8.5	1	-	500	200	75	30	250	200	0							
Permissible Limit in absence of alternate source												NA	5.0	-	2000	600	200	100	1000	600	1.5							
												Unit	NTU	m/s	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l							

*(a) Throughout any year, 95% of the samples should not contain coliform organisms in 100ml, (b) No sample should contain more than 10 coliform organisms per 100ml, (c) Coliform organisms should not be detected in 100ml of any two consecutive samples.


Principal
 Virtuous International K-12 School
 Hajipur, Vaishali (Bihar)


Chairman
 Virtuous International K-12 School
 Hajipur, Vaishali (Bihar)


25-05-2024
रसायनज्ञ
 लोक स्वास्थ्य प्रसंगल
 हाजीपुर